

# Declaration of conformity

(in accordance with ISO/IEC 17050-1)

We **IMI Hydronic Engineering**  
**Olewin 50A, 32-300 Olkusz**

in accordance with the following Directive(s):

**2014/68/EU**      **Pressure Equipment Directive (PED)**

Type:	PED Category	Conformity Assessment Module	CE Mark
PN 16, DN 20-50 PN 25, DN 20-40	SEP	SEP	NO
PN 16, DN 65-200 PN 25, DN 50-125	Category I	A	YES
PN 16, DN 250-400 PN 25, DN 150-250	Category II	H	YES (0409)
PN 25, DN 300-400	Category III	H	YES (0409)

hereby declare that the equipment:

**STAF, STAF-SG**      **Balancing valve**

is in conformity with the applicable requirements of the following document(s):

Harmonized standards:

Ref. no.	Title	Edition/date
<b>BS 13789</b>	Industrial valves. Cast iron globe valves	2010
<b>ISO 1563</b>	Foudning. Spheroidal graphite cast irons.	2018
<b>ISO 12266-1</b>	Industrial valves - Testing of metallic valves - Part 1: Pressure tests, test procedures and acceptance criteria - Mandatory requirements	2012
<b>ISO 12516-3</b>	Valves - Shell design strength - Part 3: Experimental method	2007

Non-harmonized standards and documents:

Ref. no.	Title	Edition/date
<b>EN 1982</b>	Copper and copper alloys - Ingots and castings	2017
<b>5-5-15 STAF, STAF-SG</b>	Technical Specification – STAF, STAF-SG	2018

# Declaration of conformity

(in accordance with ISO/IEC 17050-1)

The product fulfills the essential safety requirements in annex I. Our conformity assessment procedure is according to **Module H** of the **Pressure Equipment Directive PED 2014/68/EU** and the notified body used is **Kiwa Inspecta Sweden AB**, No. 0409. Certificate No. PPC 22513.

Our Integrated Management System is certified by **TÜV SÜD Management Service GmbH** in accordance with:

Ref. no.	Title	Edition/date
<b>EN ISO 9001</b>	Quality management system	2015
<b>EN ISO 14001</b>	Environmental management system	2015
<b>EN ISO 45001</b>	Occupational Health and Safety Management system	2018
<b>EN ISO 50001</b>	Energy management system	2018

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Name: Piotr Król  
Position: Quality Manager  
City: Olkusz  
On: 2021-04-28

