

# EU Declaration of Conformity



We, **IMI Hydronic Engineering**, Olewin 50A, 32-300 Olkusz, Poland under the sole responsibility of the manufacturer, hereby declare that:

Product:	Intended use:
TA-Modulator	Pressure independent balancing and control valve for modulating control

Important informations:			
Type:	PED Category	Conformity Assessment Module	CE Mark
DN 15-50, PN 16	Art. 4 p.3	SEP	NO
DN 65-200, PN 16 DN 65-125, PN 25	Category I	Module A	YES
DN 150-200, PN 25	Category II	Module H	YES

is/are compliant with the relevant Union harmonisation legislation:


Ref. no.:	Title:
Directive 2014/68/EU	Pressure Equipment Directive (PED)

and to the relevant harmonised and other standards used or to the technical specifications:

Ref. no.:	Title:
EN 12516-3:2002	Valves - Shell design strength - Part 3: Experimental method
EN 12266-1:2012	Industrial valves - Testing of metallic valves - Part 1: Pressure tests, test procedures and acceptance criteria - Mandatory requirements
EN 1092-2:1997	Flanges and their joints - Circular flanges for pipes, valves, fittings and accessories, PN designated - Part 2: Cast iron flanges
EN 12165:2016	Copper and copper alloys -- Wrought and unwrought forging stock
EN 1563:2018	Founding -- Spheroidal graphite cast irons

Manufacturer declares that Notified Body no. 0409 - Kiwa Inspecta AB, Box 7178 , 170 07 Solna, Sweden carried out the Conformity based on full-quality assurance (module H) and issued the certificate no. PPC 22513 rev.4.

Olkusz, 30.08.2023



Piotr Król  
Quality Manager