

Statement of Conformity

(in accordance with ISO/IEC 17050-1)

We **IMI Hydronic Engineering Deutschland GmbH**
Völlinghauser Weg 2, 59597 Erwitte, Germany

hereby declare that the equipment:

Raditec

are manufactured by *Idrosanitaria Bonomi S.p.A*
in accordance with the following Directive(s):

-

Official Declaration of Conformity offered by *Idrosanitaria Bonomi S.p.A* is available on the next page.

In addition we declare that our Integrated Management System is certified by **TÜV SÜD Management Service GmbH** in accordance with:

Ref. no.	Title	Edition/date
EN ISO 9001	Quality management system (cert.: QM 01024)	2008
EN ISO 14001	Environmental management system (cert.: UM 01024)	2009
EN ISO 50001	Energy management system (cert.: EnM 01024)	2011
OHSAS 18001	Occupational Health and Safety Management (cert.: OHSAS 01024)	2007

Name: Guido Grimm
Position: Quality Manager
City: Erwitte
On: 2018-03-26

IMI Hydronic Engineering
IMI Hydronic Engineering
Deutschland GmbH
Völlinghauser Weg · D-59597 Erwitte

Engineering
GREAT
Solutions

IMI PNEUMATEX

IMI TA

IMI HEIMEIER



CONFORMITY AND QUALITY OF PRODUCTS

Idrosanitaria Bonomi S.p.A., with seat in Lumezzane (Brescia - Italy), declares, under its own responsibility, that the following product:

RADIATOR VALVE ART. 5601 – 5602 – 5603 – 5604

used for civil, industrial and hydro plants, have been:

- *projected, built and tested in observance to the internal Quality system certified by Tüv-Süd, in accordance with the norm UNI EN ISO 9001:15;*
- *produced with raw materials certified in conformity with UNI EN 12165-CW617N and UNI EN 12164-CW617N, Connector O-ring in NBR and other O-rings EPDM PEROX*
- *These valves were projected in order to be resistant from a minimal temperature of 0° C to a maximal temperature of + 95° C and they have a nominal maximal pressure of 10 bar*

IDROSANITARIA BONOMI SpA
Quality Manager
Massimo Plati

Engineering
GREAT
Solutions

 **IMI PNEUMATEX**

 **IMI TA**

 **IMI HEIMEIER**